

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	82 - Coast Mountains
<b>School Name:</b>	Nechako Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: September
	Date of next inspection: December plus daily system monitoring
	Date and type of most recent maintenance: Inspect and filter change
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Increase outside air intake for more fresh air and air exchanges. Extend HVAC running schedule (to exchange air prior to occupancy)
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade): Merv 8 as per system design/specifications
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: Managed through automated control system monitored daily by maintenance facility staff.
<b>Other Relevant Information:</b>	None
<b>District Contact for any Questions:</b>	Name:
	Phone Number:
	Email: maintenance@cmsd.bc.ca